



Rosehill Water Treatment Plant

Regional Municipality of Niagara

2025 Annual Water Quality Report

(Prepared under Ontario Regulation 170/03)

January 1 to December 31, 2025

Ministry of the Environment, Conservation and Parks

Municipal Drinking Water License # 007-103

Drinking Water Works Permit # 007-203

Rosehill Water Treatment Plant – 2025 Annual Water Quality Report

This annual water quality report summarizes the quality of drinking water from the Rosehill Water Treatment Plant, drinking water system number 220002020, from January 1 to December 31, 2025.

This report satisfies the requirements of Ontario Regulation 170/03 – Drinking Water Systems.

Description of Drinking Water System

A conventional surface water treatment plant incorporates the following steps in its purification process:

- Zebra mussel control
- Travelling screens
- Coagulation
- Flocculation
- Sedimentation
- Filtration
- Disinfection
- pH correction

The plant has a rated daily flow capacity of 50,000 m³/day. Primary disinfection is achieved with sodium hypochlorite.

The Rosehill Water Treatment Plant supplies water to the Town of Fort Erie (260004904) in the Niagara region. The Rosehill Water Treatment Plant is located at 300 Rosehill Road, Fort Erie, Ontario.

The water treatment chemicals used over this reporting period are:

- Sodium Hypochlorite
- Aluminum Sulphate
- Sodium Hydroxide

Water Treatment Plant Infrastructure / System Infrastructure

Monetary Expenses:

To ensure safe and efficient operations, the following major repairs or upgrade projects took place:

- | | |
|---|-------------|
| • New Fort Erie Elevated Water Tank (In Progress) | \$6,837,152 |
| • Rosehill New Intake and Outfall (In Progress) | \$114,685 |
| • Rosehill WTP Intake Pipe Cleaning (Complete) | \$110,161 |

Summary of Adverse Water Quality Incidents

The following table summarizes the notices of adverse water quality incidents submitted in accordance with the Safe Drinking Water Act. Adverse water quality incidents are reported to the Spills Action Centre and the Medical Officer of Health.

Where there have been no adverse water quality incidents for the reporting period, the table will show "NIL".

Incident Date	Location	Adverse Condition	Corrective Action	Notice of Issue Resolution
May 22 nd , 2025	Rosehill WTP	Total coliform of 2 CFU/100mL on Ridgeway Distribution sample taken on May 20, 2025 at 11:40 am. Chlorine results were 0.85 mg/L free and 0.99 mg/L total.	Upon receipt of the initial adverse results, the Town of Fort Erie staff were dispatched to flush at the nearest hydrant at 14 Ridgeway Road on Thursday May 22, 2025. Samples were taken by Niagara Region staff upstream at the Rosehill WTP, at the source at the Ridgeway Distribution Sample Station, and downstream at the Stevensville Reservoir. Resamples showed no total coliform.	May 26 th , 2025
June 16 th , 2025	Rosehill WTP	Possible unmonitored filter effluent turbidity event. On June 16th, 2025 at 16:18 pm, Filter 4 at the Rosehill WTP was observed to have a visible alarm on the filter's turbidimeter transmitter.	The operator immediately shut the filter down. Upon reviewing the filter turbidity data, the turbidimeter transmitter failed at approximately June 16th at 14:11 pm. During the 2 hours and 7 minutes the filter was in operation in this state, it produced approximately 550 m3 of water to the clearwell. The operator also took a grab sample at the same time, and it	June 19 th , 2025

Incident Date	Location	Adverse Condition	Corrective Action	Notice of Issue Resolution
			was 0.047 NTU. Instrumentation staff replaced and calibrated the transmitter on Filter 4 and operations placed the filter back into service. All coagulant and reservoir chlorine/CT processes were in service with no issues during this time.	

Water Quality Test Results

Reported results that are shown with “ND” (non-detect) instead of a numerical value indicates that the sample result is below the lowest possible detection limit for the parameter.

Microbiological Testing

Microbiological testing carried out under Schedule 10 of Ontario Regulation 170/03 – Drinking Water systems, during this reporting period.

Location	Number of Samples	Range of E.Coli Results (minimum number)-(maximum number)	Range of Total Coliform Results (minimum number)-(maximum number)	Prescribed Standard*	Unit of Measure
Raw	52	0 - 128	0 – 1680	Not applicable	CFU/100ml
Treated	107	0	0	Not detectable	CFU/100ml
Distribution	158	0	0 - 2	Not detectable	CFU/100ml

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards.

Heterotrophic Plate Count Testing

Heterotrophic plate count (HPC) testing is conducted on some treated and distribution system samples. The HPC test is used as a tool to monitor overall quality, but the results are not indicators of water safety. There is no prescribed standard for HPC.

Location	Number of Samples	Range of HPC Results (minimum number)-(maximum number)	Unit of Measure
Treated	107	0 - 3	CFU/ml
Distribution	158	0 - 5	CFU/ml

Operational Testing

Operational testing carried out under Schedule 7 of Ontario Regulation 170/03 – Drinking Water Systems, during this reporting period. An analyzer continuously monitors the water treatment process and records results on a predetermined frequency.

Where continuous monitors are used, 8760 is reflected as the number of samples.

Parameter	Number of Samples	Range of Results (minimum number)-(maximum number)	Unit of Measure
Filter Turbidity	8790	0.011 - 0.839	NTU*
Treated Chlorine	8790	0.40 - 2.00	mg/L

*NTU (nephelometric turbidity units) is a unit that measures the lack of water clarity.

Additional Testing

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of Legal Instrument Issued	Location: Parameter	Date Sampled	Result Value or Range (minimum number)-(maximum number)	Requirement	Unit of Measure
Municipal Drinking Water License Issue 12 December 16, 2024	Environmental Discharge: Free Chlorine Residual	Per Event	0 – 0.02	< 0.02	mg/L
Municipal Drinking Water License Issue 12 December 16, 2024	Environmental Discharge: Total Suspended Solids	Monthly (January – December)	<3-17	25 (Running Annual Average)	mg/L
Municipal Drinking Water License Issue 12 December 16, 2024	Raw: Microcystin	Weekly (June – October)	ND – 0.00018	0.0015*	mg/L
Municipal Drinking Water License Issue 12 December 16, 2024	Treated: Microcystin	Weekly (June – October)	ND	0.0015*	mg/L

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards.

Inorganic Testing

Inorganic parameter testing carried out under Schedule 13 of Ontario Regulation 170/03 – Drinking Water Systems, during this reporting period. Inorganic substances include heavy metals and dissolved minerals that may be present in treated drinking water.

Parameter	Number of Samples	Last Sample Date	Range of Results (minimum number)- (maximum number)	Prescribed Standard*	Unit of Measure	Exceedance
Antimony	4	2025-11-03	ND	0.006	mg/L	No
Arsenic	4	2025-11-03	ND	0.01	mg/L	No
Barium	4	2025-11-03	0.019 – 0.03	1.0	mg/L	No
Boron	4	2025-11-03	0.021 – 0.037	5.0	mg/L	No
Cadmium	4	2025-11-03	ND	0.005	mg/L	No
Fluoride	12	2025-11-03	ND – 0.08	1.5	mg/L	No
Mercury	4	2025-11-03	ND	0.001	mg/L	No
Nitrate	12	2025-11-03	ND – 0.28	1.0	mg/L	No
Nitrite	12	2025-11-03	ND	1.0	mg/L	No
Selenium	4	2025-11-03	ND – 0.0006	0.05	mg/L	No
Sodium	4	2025-11-03	13 – 15.3	20	mg/L	No
Uranium	4	2025-11-03	ND	0.02	mg/L	No

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards. The prescribed standard for sodium is copied from Ontario Regulation 170/03 – Drinking Water Systems.

Lead Testing

Lead testing carried out under Schedule 15.1 of Ontario Regulation 170/03 – Drinking Water Systems, during this reporting period.

Location	Number of Samples	Last Sample Date	Range of Lead Results (minimum number)- (maximum number)	Prescribed Standard*	Unit of Measure	Exceedance
Treated	4	2025-11-03	ND – 0.0004	0.010	mg/L	No
Distribution	4	2025-11-03	ND	0.010	mg/L	No

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards.

Organic Testing

Organic parameter testing carried out under Schedule 13 of Ontario Regulation 170/03 – Drinking Water Systems, during this reporting period. Trace organic test parameters include volatile organic substances, pesticides, solvents, dioxins, PCB's, and disinfection by-products.

Parameter	Number of Samples	Last Sample Date	Range of Results (minimum number)-(maximum number)	Prescribed Standard*	Unit of Measure	Exceedance
1,1-Dichloroethylene (vinylidene chloride)	4	2025-11-03	ND	0.014	mg/L	No
1,2-Dichlorobenzene	4	2025-11-03	ND	0.2	mg/L	No
1,2-Dichloroethane	4	2025-11-03	ND	0.005	mg/L	No
1,4-Dichlorobenzene	4	2025-11-03	ND	0.005	mg/L	No
2,3,4,6-Tetrachlorophenol	4	2025-11-03	ND	0.1	mg/L	No
2,4,6-Trichlorophenol	4	2025-11-03	ND	0.005	mg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	4	2025-11-03	ND	0.1	mg/L	No
2-4 Dichlorophenol	4	2025-11-03	ND	0.9	mg/L	No
2-Methyl-4-chlorophenoxyacetic acid (MCPA)	4	2025-11-03	ND	0.1	mg/L	No
Alachlor	4	2025-11-03	ND	0.005	mg/L	No
Atrazine + N-dealkylated metabolites	4	2025-11-03	ND	0.005	mg/L	No
Azinphos-methyl	4	2025-11-03	ND	0.02	mg/L	No
Benzene	4	2025-11-03	ND	0.001	mg/L	No
Benzo(a)pyrene	4	2025-11-03	ND	0.00001	mg/L	No
Bromoxynil	4	2025-11-03	ND	0.005	mg/L	No
Carbaryl	4	2025-11-03	ND	0.09	mg/L	No
Carbofuran	4	2025-11-03	ND	0.09	mg/L	No
Carbon Tetrachloride	4	2025-11-03	ND	0.002	mg/L	No
Chlorobenzene	4	2025-11-03	ND	0.03	mg/L	No
Chlorpyrifos	4	2025-11-03	ND	0.09	mg/L	No
Diazinon	4	2025-11-03	ND	0.02	mg/L	No
Dicamba	4	2025-11-03	ND	0.12	mg/L	No
Dichloromethane	4	2025-11-03	ND	0.05	mg/L	No
Diclofop-methyl	4	2025-11-03	ND	0.009	mg/L	No

Parameter	Number of Samples	Last Sample Date	Range of Results (minimum number)-(maximum number)	Prescribed Standard*	Unit of Measure	Exceedance
Dimethoate	4	2025-11-03	ND	0.02	mg/L	No
Diquat	4	2025-11-03	ND	0.07	mg/L	No
Diuron	4	2025-11-03	ND	0.15	mg/L	No
Glyphosate	4	2025-11-03	ND	0.28	mg/L	No
HAA – Distribution (latest running annual average)	12	2025-12-01	0.019	0.080 (running annual average)	mg/L	No
Malathion	4	2025-11-03	ND	0.19	mg/L	No
Metolachlor	4	2025-11-03	ND	0.05	mg/L	No
Metribuzin	4	2025-11-03	ND	0.08	mg/L	No
Paraquat	4	2025-11-03	ND	0.01	mg/L	No
Pentachlorophenol	4	2025-11-03	ND	0.06	mg/L	No
Phorate	4	2025-11-03	ND	0.002	mg/L	No
Picloram	4	2025-11-03	ND	0.19	mg/L	No
Polychlorinated Biphenyls (PCB)	4	2025-11-03	ND	0.003	mg/L	No
Prometryn	4	2025-11-03	ND	0.001	mg/L	No
Simazine	4	2025-11-03	ND	0.01	mg/L	No
Terbufos	4	2025-11-03	ND	0.001	mg/L	No
Tetrachloroethylene	4	2025-11-03	ND	0.01	mg/L	No
THM – Distribution (latest running annual average)	12	2025-12-01	0.031	0.100 (running annual average)	mg/L	No
Triallate	4	2025-11-03	ND	0.23	mg/L	No
Trichloroethylene	4	2025-11-03	ND	0.005	mg/L	No
Trifluralin	4	2025-11-03	ND	0.045	mg/L	No
Vinyl Chloride	4	2025-11-03	ND	0.001	mg/L	No

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards.

Parameters Exceeding Prescribed Half-Standard

Any inorganic or organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of prescribed standards documented in Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards or prescribed standards documented within Ontario Regulation 170/03 – Drinking Water Systems for large municipal residential drinking water systems.

Where there have been no instances of a half-standard exceedance for the reporting period, the table will show “NIL”.

Parameter	Result Value or Range (minimum number)-(maximum number)	Prescribed Standard*	Unit of Measure	Date of Sample
Sodium	13 – 15.3	20	mg/L	2025-02-03 2025-05-05 2025-08-05 2025-11-03

*Prescribed standards are copied from Ontario Regulation 169/03 - Ontario Drinking Water Quality Standards. The prescribed standard for sodium is copied from Ontario Regulation 170/03 – Drinking Water Systems.